

# 電線電纜用鍍鋅鋼製導線管

中華民國國家標準 CNS 2606 C4060 – Galvanized Steel Conduits for Electrical Wires and Cables

日本工業規格 JIS C8305 – Rigid steel conduits

## 厚鋼電線管尺度、重量 Dimension, mass, tolerances on outside diameter and mass of thick rigid steel conduit tubes

Designator 管之稱呼	Outside Diameter 外徑	Tolerance on Outside Diameter 外徑之容許差	Thickness 厚度	Inside Diameter 近似內徑	Mass 重量
	mm	mm	mm	mm	Kg/m
G 16	21.0	± 0.3	2.3	16.4	1.06
G 22	26.5	± 0.3	2.3	21.9	1.37
G 28	33.3	± 0.3	2.5	28.3	1.90
G 36	41.9	± 0.3	2.5	36.9	2.43
G 42	47.8	± 0.3	2.5	42.8	2.79
G 54	59.6	± 0.3	2.8	54.0	3.92
G 70	75.2	± 0.3	2.8	69.6	5.00
G 82	87.9	± 0.3	2.8	82.3	5.88
G 92	100.7	± 0.4	3.5	93.7	8.39
G 104	113.4	± 0.4	3.5	106.4	9.48

## 無螺紋電線管尺度、重量 Dimension, mass, tolerances on outside diameter and mass of threadless rigid steel conduit tubes

Designator 管之稱呼	Outside Diameter 外徑	Tolerance on Outside Diameter 外徑之容許差	Thickness 厚度	Inside Diameter 近似內徑	Mass 重量
	mm	mm	mm	mm	Kg/m
E 19	19.1	± 0.15	1.2	16.7	0.53
E 25	25.4	± 0.15	1.2	23.0	0.72
E 31	31.8	± 0.15	1.4	29.0	1.05
E 39	38.1	± 0.15	1.4	35.3	1.27
E 51	50.8	± 0.15	1.4	48.0	1.71
E 63	63.5	± 0.25	1.6	60.3	2.44
E 75	76.2	± 0.25	1.8	72.6	3.30

鍍鋅鋼管之重量許可差為 -7%，正許可差部分不予規定